Volume 22 Issue 10
Originally issued as H3



Global Journal of Science Frontier Research: H
Environment & Earth Science
Volume 22 Issue 2 Version 1.0 Year 2022
Type: Double Blind Peer Reviewed International Research Journal
Publisher: Global Journals
Online ISSN: 2249-4626 & Print ISSN: 0975-5896

Low-Cost, Energy-Efficient and Carbon-Saving Dry Ice Air Conditioning System - A Possible By-Product of a Novel and Highly Cost-Effective Carbon Capture Technology

By Dilip K. De & Idowu B. Oduniyi

Abstract- To combat global warming and climate change, it is necessary to have technologies for the low cost capture of carbon dioxide (CO2) and the associated toxic components of the flue gas emissions from industries and for the low-cost storage and utilization of the captured CO2. This paper presents a brief description of a new technology for emission capture (NTEC) to capture nearly 100% of the CO2 from industrial emissions in the form of liquefied CO2 and dry ice, very cost effectively, at -$14 to $23 per ton of CO2 captured, depending on whether the power is generated by coal or natural gas and the CO2 concentration in the flue gas. The negative sign means the capture generates additional auxiliary energy for the industry. NTEC is patented in the USA (No. 10670334 B2 June 2, 2020). Using dry ice that could be abundantly available with NTEC, the proposed future technology of a dry ice air conditioning system is presented. Assuming that dry ice is not more than $80 per ton with NTEC, then, for air conditioning a house of area 256 sq. m. (the inside temperature maintained 24 hrs 7 days/wk at 70 F, while the outside temperature is at 102 F for 12 hrs), it would save $160 in a hot summer month.

Keywords: emissions from industries, novel technology of emission capture, carbon capture, environmental pollution and climate mitigation, lowest energy and cost of capture, dry ice air conditioning, cost and carbon saving.

GJSFR-H Classification: DDC Code: 628.5 LCC Code: TD885.5.C3



Strictly as per the compliance and regulations of:



© 2022. Dilip K. De & Idowu B. Oduniyi. This research/review article is distributed under the terms of the Attribution-NonCommercial-NoDerivatives 4.0 International (CC BY-NC-ND 4.0). You must give appropriate credit to authors and reference this article if parts of the article are reproduced in any manner. Applicable licensing terms are at https://creativecommons.org/licenses/by-nc-nd/4.0/.

Low-Cost, Energy-Efficient and Carbon-Saving Dry Ice Air Conditioning System - A Possible By-Product of a Novel and Highly Cost-Effective Carbon Capture Technology

Dilip K. De [α] & Idowu B. Oduniyi [σ]

Abstract- To combat global warming and climate change, it is necessary to have technologies for the low cost capture of carbon dioxide (CO2) and the associated toxic components of the flue gas emissions from industries and for the low-cost storage and utilization of the captured CO2. This paper presents a brief description of a new technology for emission capture (NTEC) to capture nearly 100% of the CO2 from industrial emissions in the form of liquefied CO2 and dry ice, very cost effectively, at -$14 to $23 per ton of CO2 captured, depending on whether the power is generated by coal or natural gas and the CO2 concentration in the flue gas. The negative sign means the capture generates additional auxiliary energy for the industry. NTEC is patented in the USA (No. 10670334 B2 June 2, 2020). Using dry ice that could be abundantly available with NTEC, the proposed future technology of a dry ice air conditioning system is presented. Assuming that dry ice is not more than $80 per ton with NTEC, then, for air conditioning a house of area 256 sq. m. (the inside temperature maintained 24 hrs 7 days/wk at 70 F, while the outside temperature is at 102 F for 12 hrs), it would save $160 in a hot summer month. Assuming that the sublimated CO2 is not captured back, then for air conditioning one house this would also save the emission at power plants of 992 kg or 290 kg of CO2 in a hot summer month if the power is generated by coal or natural gas respectively. The paper also discusses an efficient technique of storing dry ice and capturing back some of the CO2 that would be emitted during sublimation of the dry ice. If the sublimated CO2 is captured back, the net carbon saving would be quite substantial with the proposed dry ice air conditioning system. The paper further discusses some of the positive impacts such technology can have on climate mitigation and the future green environment.

Keywords: emissions from industries, novel technology of emission capture, carbon capture, environmental pollution and climate mitigation, lowest energy and cost of capture, dry ice air conditioning, cost and carbon saving.

Author α σ: Sustainable Green Power Technologies, Mansfield, Texas 76063, USA. e-mail: dilip.de@covenantuniversity.edu.ng

I. Introduction

a) Carbon emission and capture

Electric power plants, and cement and steel industry facilities, release flue gas (FG) that contains a large amount of pollutants, along with hot steam and unreacted nitrogen. The pollutants include fly ash, carbon dioxide (CO2), the associated toxic components (ATCs), such as nitrogen oxides (NOx, x = 0.5,1,1.5,2,2.5), sulfur oxides (SOy, y = 2,3), mercury (Hg) and its oxides, oxides of some other metals, acid vapors, volatile organic compounds (VOCs), soot, and particulate matter (PM) [1,1a-g]. With the existing state of the art, clean energy technologies' capture of the polluting components and CO2 is very costly and materials intensive [1-45, 45a-w].

These pollutants cause environmental damage and contribute to global warming. Literature abounds on the nature of these emissions and their effect on health [2a-g] and the environment [1- 45a], including ocean acidification [45b]. There is also literature on the current state-of-the-art technologies for capturing these emissions, and the cost implications to control the emissions in part or in full [1-45]. By studying all this literature [1-61], we find that:

1. The emission capture technologies developed so far are still quite expensive [23,24,25,45h,50], and 100% capture of the components (e.g. CO2, NOx, SOx, CO, Hg) is still not possible.
2. The technology for storing CO2 under high pressure in an empty coal or oil field [45a-h, 55, 1b-1g] is still quite expensive, and leakage into the atmosphere is a possibility. It involves compression to high pressure (2500 to 3000 psi) and passing through hundreds or thousands of miles of pipelines into underground geological formations [5a-h]. The stored CO2 may be mixed with impurities, and rapid utilization of the stored or captured CO2 is not possible. The oldest power stations may be uneconomical to retrofit with modern amine scrubbing technologies. The cost of capture of gaseous CO2 by amine scrubbing still ranges between $40 and $61 per ton of CO2 captured.

© 2022 Global Journals

3. Various technologies are used to capture carbon dioxide from the air, an industrial source or a power plant flue gas. These include absorption, adsorption, chemical looping, or membrane gas separation technologies [45c]. The leading carbon capture technology uses various forms of amines [45a-f]. Even though modern CO2 capture technologies could reduce the CO2 emissions to the atmosphere by approximately 80- 90%, they increase the cost of electricity by an additional 21-91%. According to experts, the additional increase in delivery cost would put a severe burden on consumers. The cost of direct carbon capture by sucking carbon directly out of the air - by using fans and absorbing it into solutions of Ca(OH)2 or KOH and then regenerating CO2 by heating the solutions - has fallen from $600 to $98-$234 per ton. It is still too expensive to be employed on a large scale.
4. With amine-based solutions for CO2 removal, SO2 must be removed by techniques such as flue-gas desulfurization (FGD), to avoid potential reactions with the amine-based solutions. However, techniques to remove NOx are often not employed to minimize the capture cost. The carbon capture results in an energy penalty of 15-25%, depending on the type of carbon capture technology employed. This leads to additional emissions of CO2 and also of NOx and PM [45g].
5. There are secondary pollutants from the chemical-based emission capture technologies developed so far, like the nitroso compounds in amine scrubbing of CO2 [60], which are carcinogenic.
6. Because of the high cost, as of 2019, there were only 17 operating carbon capture and sequestration (CCS) projects in the world, capturing 31.5 million tons of CO2 per year, of which 3.7 million tons is stored geologically [45e].
7. According to an organization which promotes CCS, it will cost $120-$140 per ton of CO2. This will add from $168 to $196 to the cost of a MWh of coal generation [61].

b) Need for a new carbon capture technology

Thus, we see that there is a need for research on the development of technologies for the low-cost capture of CO2 and the ATCs of the FG emission and the storage of CO2 and its utilization. This paper presents a brief description of a new technology for emission capture (NTEC) which would capture industrial emissions, CO2 and the ATCs, at a nearly 100% rate, using less energy and at a cost lower than the lowest of all existing technologies [5]. This paper's main thrust is on very cost-effective storage of the vast amount of dry ice that would be available using NTEC in the future and the use of the dry ice for future air conditioning to save carbon and consumers' cost. References for sections I.1 and I.2 are given in Appendix C. NTEC has been patented in Jun 2, 2020[US patent No. 10670334] by the authors.

Modern refrigeration and air conditioning (AC) systems consume a significant amount of electric energy [1-3], generation of which gives rise to emissions of CO2 and many toxic components which not only contribute to global warming but also have many environmental effects ([2a-g] of Appendix C). The cost of running the dry ice AC is analyzed and compared with current AC, and a method of storing the dry ice that would be available with NTEC is described. The carbon saving from the future use of such air conditioning systems is discussed. Finally, the positive environmental effect it would have in the future is discussed.

II. A Vast Amount of Dry Ice to be Available using NTEC

Below we describe our novel technology, NTEC, to capture CO2 and the other components of the FG (Fig. 1). This method is very cost effective, does not require the use of any chemicals, and only needs a fixed amount of water which can be used repeatedly. The basic principle of this new technology has been intensively studied by the authors [5]. We describe below the key novelties of NTEC over other emission capture technologies. A brief description of the key principles and methods involved is given in Appendix D.

© 2022 Global Journals




Fig. 1: Schematic diagram of the equipment based on NTEC to capture CO2 and the toxic components of the FG from power plants most cost-effectively with very high energy efficiency (244 MJ per ton of CO2 from a coal power plant and -237 MJ per ton of CO2 from a natural gas power plant. The US patent No. 10670334 B2, with 18 sub-claims for the above equipment, and 19 process claims have been issued on June 2, 2020.

a) Key Novelties of NTEC over other Cryogenic Technologies

Fig. 1 schematically describes the methods of NTEC that include the following novelties: (i) generation of auxiliary power (AUP) from the heat of the FG, in order to lessen the dependence on energy from the main output of the power plant, and thus also cooling the FG to the ambient temperature before compression; the theory of this can be seen in detail in the authors' US patent [5]; (ii) isentropic compressions by 15 compressors, each compression being at increasing steps of 1.8 to 2 bars, and cooling the compressed FG after each compression by cold nitrogen gas (CNG), until the FG reaches ~27 bars pressure at temperature ~11 C in a special heat exchanger [5] (at e2 in Fig. 1), where the CO2 of the compressed FG condenses fast (Fig. 2) to liquefied cold CO2 (LCO2 in Fig.1); this reduces the net compression work more than a single compression and cooling (see Appendix E), and to a value much lower than that of previous workers [23b-d,24]; LCO2 can be converted to dry ice as needed (Fig.1); (iii) further cooling the FG (after capture of CO2) in a heat exchanger (at e3 in Fig.1), and generating CNG (at -195 C to -194 C) from the unreacted nitrogen gas by three-stage turbine expansion (at points f-g-h-i in Fig.1); (iv) cooling the FG in heat exchangers (between points a and i in Fig. 1) by the CNG for very fast heat exchange between the flowing FG and the CNG; (v) utilizing the turbine expansion work for compression of the FG using a shaft (Fig.1); (vi) using no chemicals and only a fixed amount of water that is reusable for many years; (vii) capturing CO2 (with purity > 99.99%) in the form of a cold liquid after capture of fly ashes, soot, SO3, NO2, H2O, each separately (for details, see Ref. 5); (viii) capturing N2O, NO and CO, each separately, during the three-stage turbine expansions after capture of CO2; (ix) freezing the dry ice by CNG and collecting dry ice in air-tight conditions; (x) taking measures all along to prevent choking of the compressors during compressions of the FG and the capture of components; (xi) all capture being accomplished using a single piece of equipment that can be fitted to a new power plant and retrofitted to an old power plant; (xii) capturing products that all have industrial demands; (xiii) NTEC does not require any storage for cryogens as required by previous works [34].

The processes involved in the capture are given in detail in Appendix D. The theories of energy of capture per ton of CO2 (EC) are provided in Appendix E. Further details can be seen in Ref. 5.

As discussed in section II.3, and seen in Tables A & B(columns A3 & A4), NTEC requires a net EC much lower than the lowest EC by all existing state-of-the-art cryogenic[see Appendix E] and chemical-based technologies [23c-31,33]. It my be noted from column A2 of Table A and Refs. 23c-31 that our technology

© 2022 Global Journals

would provide a much lower cost of CO2 capture even if we eliminate AUP. With AUP, this is the only technology that would enable capture of CO_2 and the ATCs from a natural gas power plant (NGPP) without requiring any energy from the main power output and yet would deliver extra energy to the grid after capture, if the FG exit temperature is 250 C or slightly higher and the dry mass CO2 concentration is more than 12.5%. For a higher temperature of the FG, the temperature can be brought down by a standard air-preheating technique and a combined power and heat cogeneration technique [32].

b) Comparison of NTEC with State-of-The-Art Co_2 Capture Technologies

With NTEC, depending on the FG temperature and whether coal or natural gas is used for power generation, CO2 can be captured at a low cost (-$14.5 to $22.5 per ton of CO2 captured (Table A)) from the FG. The negative dollar value indicates extra energy generated (profit) during capture of CO2 from a NGPP using NTEC when the CO2 dry mass concentration (DMC) in the FG is more than 12.5%. Dry ice has many applications which could be further extended with NTEC. There is no recurrent expense of materials for the capture of emissions and most of the toxic components of the FG are captured at no additional cost. Unlike current state-of-the-art capture technologies [23c-31], there is no secondary emission with NTEC. Many secondary emissions are carcinogenic.

Using high pressure, 100-200 bars, Baxter et al. [23c] found the minimum EC for liquefaction to be 700 MJ per ton of CO2 for an oxyfuel combusted power plant (98% CO2 concentration by weight). The corresponding energy with NTEC would be 191 MJ if we do not use AUP and turbine work (TW). With AUP and TW, these would produce surplus energy with our method. Now, in a simulated model of carbon capture from an oxyfuel combusted FG, Toleuova et al. [24] found that the minimum energy needed was 0.18 MWh, which is equivalent to 648 MJ per ton of CO2.

According to Keith et al. [26], using the latest technology of capturing CO2 directly from the air (using alkali to absorb it and then heating the alkali to regenerate it), the energy cost is approximately 8800 MJ of natural gas, or 5250 MJ of natural gas and 366 kWh of electricity per ton of CO2 captured. The levelized cost now ranges between $94 and $232 per ton of CO2 for direct air-capture. Faishi et al. [27] gives an excellent review of all the studies of the cost of direct CO_2 capture from the air and the lowest cost (5526 MJ/tCO_2) exceeds by far our high cost of carbon capture, 1276 MJ/tCO2 from a coal power plant, and 341 MJ/tCO2 from a natural gas power plant (Table A, columns A3 & A4). Direct CO2 capture from the air has been increasingly discussed as a climate change mitigation option. However, even with the latest developments, the cost is still quite high.

Zanganeh et al.'s experimental studies [28] showed that the cryogenic technique is most cost effective when the feed gas is available at high pressure and high concentration as in the FG of oxyfuel combustion. For gas mixtures with high initial pressure and high CO2 concentration (90% in a CO2/H2 mixture), Xu et al. [29] studied a technique comprising a two-stage compression, two stage refrigeration, and two-stage separation with recovery of cryogenic energy, and found that CO2 can be captured at 395 MJ/tCO2. NTEC offers much lower EC (maximum 188.5 MJ/ton) for oxyfuel combustion without TW and without AUP (100% CO2 concentration, Table A). With TW and AUP the EC is negative, meaning generation of excess energy.

Song et al.'s studies [30] revealed that under the optimal temperature and flow rate, CO2 recovery of the cryogenic process can reach 96% with 1500 MJ/tCO2 energy consumption. Tuinier et al. [31] found that more than 99% of CO2 could be recovered from a FG containing 10% (v/v) (15% DMC) CO2 and 1 % (v/v) H2O with 1800 MJ/tCO2 energy consumption, using a novel cryogenic CO2 capture process that uses dynamically operated packed beds. Comparing results (700 MJ in column A3) & (-237 MJ/tCO2 in column A4) (Tables A & B), one can see that our technique surpasses all the above mentioned technologies. Thus, our patented technology with no secondary emission is superior to previous technologies also in terms of the cost of capture of CO2. Unlike ours, they have not focused on the dependence of the capture energy on the CO2 concentration in the gas mixture. Unlike current SOAs NTEC has potential to produce power with net zero emission.

c) Amount of Dry Ice that can be Captured by NTEC

Considering the case of the total energy generation, $1.4x10^{18}$ J, in the UK in 2010 and the analysis by Dr. Clifford Jones of the total CO_2 emitted [5a], and considering the fact that NTEC is capable of capturing at a near 100% rate, the total dry ice that can be captured is 587 million tons if the power is generated by coal, and 198 million tons if the power is generated by natural gas [5]. Even utilization of only a 50% capture rate would contribute significantly towards the mitigation of climate change. The vast amount of dry ice thus captured would enable the use of dry ice refrigeration and air conditioning that would contribute further towards climate mitigation (see section III).

© 2022 Global Journals




Fig. 2 [5]: The temperature entropy of CO2 for production of liquefied CO2 and dry ice using the new technique

Table A: Modeled values of power plant energy (EC) needed (and the cost) to capture 1 ton of CO2 in liquid form (ELCO2), and most of the ATCs (separately), with different CO2 concentrations under various capture conditions of NTEC, using 15 compressors. (Proprietary of Sustainable Green Power Technologies (SGPT) and US Patent 10670334 B2 dated June 2, 2020)[!]

DMC of CO2 (%)	DMC of N2 (%)	A1	A2	A3 Coal		A4 Natural Gas	
		Energy (MJ)		Energy (MJ)	Cost* ($)	Energy (MJ)	Cost* ($)
10	90	2861	1744	1268	23	333	6
15	85	1876	1174	700	12	-237	-4
20	80	1378	879	403	7	-532	-9
22	78	1244	805	329	6	-606	-11
25	75	1082	710	244	4	-701	-$13
30 100[!!]	70 0	883 188.5	594 ---	118 --	$2 --	-817 --	-$14 --

[!]We assume 35% efficiency of power generation, and that the exit exhaust FG with temperature between 250 C and 300 C can raise the ammonia temperature in the auxiliary power generator to 200 C. If the temperature of the exit FG from the power plant is higher than 300 C, it can be brought down using combined heat and power [32] and an air preheater (APH). See Appendix E for methods of calculations of EC.

DMC (Dry mass concentration) - the percentage of mass in the mixture after H2O, SO3, NO2, SO2, soot, VOCs, etc. are removed from the FG. Vol(%) =28xDMC/(44-DMCx0.16) The corresponding volume concentration is slightly more than half.

A1- Energy from a power plant needed to liquefy 1 ton of CO2 (ELCO2) without turbine work (TW), without auxiliary power (AUP), but with cooling by an external liquid nitrogen source (ELNS)

A2- ELCO2 with TW, with cold N2 gas cooling (CNG), but without AUP and without ELNS

A3- ELCO2 with TW, with AUP, with CNG, but without ELNS

© 2022 Global Journals

A4- ELCO2 with TW, with AUP, with CNG, but without ELNS

[!!]With oxyfuel combustion, the DMC is 100%. For this DMC tentative values are given in columns A2,A3 &A4. Investigation on correct values for these columns are continuing.

*The cost is evaluated using the cost of electricity at generation point, $0.0644/kWh [Table 3 of Ref. 33]. For other concentrations, and for much lower FG temperatures, we are collecting data to compute the energy values. The values with finite AUP are expected to be significantly less than those with no AUP.

Table A (Recalculated): Modeled values of power plant energy needed (and the cost) to capture 1 ton of CO2 in liquid form (ELCO2), and most of the ATCs (separately), with different CO2 concentrations under various capture conditions of NTEC, using 15 compressors. (Proprietary of Sustainable Green Power Technologies (SGPT) and US Patent 10670334 B2 dated June 2, 2020)[!].

DMC of CO2 (%)	DMC of N2 (%)	A1	A2	A3 Coal		A4 Natural Gas	
		Energy (MJ)		Energy (MJ)	Cost* ($)	Energy (MJ)	Cost* ($)
10	90	2868	1752	1276	23	341	6
15	85	1876	1173	697	12	-238	-4
20	80	1379	883	407	7	-528	-9
22	78	1244	804	328	6	-606	-10
25	75	1082	710	234	4	-701	-12
30 100[!!]	70 0	883 189	594 189	118 -287	2 -5	-817 -1292	-14 -23

Table B: Modeled energy (EC) from a power plant needed to capture CO2 at different concentrations in the FG exiting a power plant and under various capture conditions. The lowest energy is in columns A3 & A4. All are the same as in Table A except 10 compressors are used

DMC of CO2	DMC of N2	A1	A2	A3 Coal	A4 Natural Gas
		Energy (MJ)	Energy (MJ)	Energy (MJ)	Energy (MJ)
0.10	0.90	2912	1796	1320	385
0.15	0.85	1903	1200	724	-211
0.20	0.80	1400	899	423	-512
0.25	0.75	1098	726	250	-685
0.30	0.70	896	607	131	-804

III. Design of the New Dry Ice Refrigeration and Air Conditioning System with Dry Ice that can be Abundantly Available with NTEC

The new dry ice refrigeration and air conditioning system is very simple compared to the existing chlorofluorocarbon-based systems. It primarily consists of a very well-insulated structure BRW (outside the main house) of inside dimensions 2.3 m x 2.3 m x 2.3 m, at the center of which there is a metal box (MB) made of aluminum plates of size 0.7 m x 0.7 m x 0.7 m (see Fig. 3a). The box MB is surrounded on all sides by slabs of dry ice (DRI in Fig. 3a) of total thickness 0.3 m. The DRI are surrounded by very good insulation (INS in Fig. 3a) made of Styrofoam (or polyurethane) and aluminum foil (for reflection). The insulation thickness is 0.5 m. The mass of the dry ice would be adequate to last for three months, assuming that the thermal insulation is good enough. There is also an additional

© 2022 Global Journals

layer of insulation of thickness 0.35 m outside and all around BRW. The metal box is connected to the house with two tubes one at the top and the other near the bottom. The bottom one conveys cold air to the house and vents it at the top of the house. The top one (HA in Fig. 3a) conveys warm air from the top of the house to the top of the metal box. The fans needed for this circulation of cold and hot air could be run by a small solar panel or a battery or even electric power and are connected to the automatic control system (CS) which sets the temperature of the house. The tubes also contain CO2 sensors to prevent leakage of CO2 into the main house. For efficient cooling, the structure of the metal box MB is as shown in Fig. 3b. The horizontal metal fins connect the opposite walls of the box with alternate gaps as shown. The walls of the box MB are kept in constant contact with the dry ice slabs through a spring system (not shown in Fig. 3a) attached to BRW. The sublimated CO2 is vented outside the house by a tube (not shown in Fig. 3a). The tube collects the CO2 from the top side of BRW and vents it to the outside near the ground in a garden.




Fig. 3a: A schematic of the future dry ice refrigeration and air conditioning system




Fig. 3b: Internal structure of the box MB in Fig. 3a to cool hot air efficiently. It contains alternate metal fins. This arrangement provides efficient cooling of the hot air (HA) from the house and generates the cold air (CA) that circulates

a) *Cost of Running the Dry Ice Air Conditioning and Comparison with Conventional Ac*

We consider a house of 256 sq. m. with internal height 4 m and with the walls and the roof covered with insulation 0.75 m and 1.5 m thick respectively. We assume that the insulation has effective thermal conductivity (0.025 W/mK) of that of rigid expanded board made of polyurethane [6]. We consider the outside temperature to remain at 102 F for 12 hrs of the day and the internal temperature of the house to be kept at 70 F. We assume that every day 25% of fresh air at 102 F enters from outside. Calculation (Appendix A) shows that the monthly consumption of dry ice will be 800 kg, if the BRW of Fig. 3a is well insulated. The consumer cost of this dry ice will be $60 per month. With conventional air conditioning a 5-ton AC [1-3] needs to run for 12 hrs a day (total) and it would consume 1800 kWh of electricity, which in Texas would cost at least $216 per month at $0.12 per kWh. Besides the cost saving of $152 per month during the summer time, it would yield a carbon saving of at least 892 kg if the

© 2022 Global Journals

entire power is generated from coal (0.94 kg CO2/kWh) and 190 kg if the entire power is generated using natural gas (0.55 kg CO2/kWh). Without NTEC, such cost and emission savings would not be possible using dry ice available at $1000 per ton [4] with current technologies.

Calculations based on a case study (Appendix A and Appendix B) show that if the inside air is at 102 F, it can be cooled to 87 F in 3 hrs, with a cool air flow rate of 0.42 kg/s (Appendix B) from MB (Fig. 3a). In about 6 hrs the house will reach 70 F (controlled by thermostat sensor in the middle of the house). Once at 70 F, the needed cool air flow rate will be 0.075 kg/s into the house to compensate for the heat flow from outside at 102 F. The internal wall temperature can be at 75 F.

Thus, substantial savings of money and carbon can be achieved using the dry ice air conditioning if the CO2 is captured using our technology. Both the new technology for emission capture, NTEC, and the dry ice air conditioning technology can self-sustain without any carbon tax or incentives from the government. Such sustainable technology can go a long way in ensuring clean energy and a green environment at the lowest cost. Moreover, abundantly available dry ice at such low cost can expand industrial uses of dry ice and the pure CO2 that can be obtained from it.

b) Storage of Vast Amounts of Dry Ice that Can Be Produced In The Future From Industrial Flue Gas Using NTEC

As discussed, the current technology of sequestrating gaseous CO2 in empty geological formations is quite expensive [1-45a-h in Appendix C]. Below we describe a simple storage technique for the storage of CO2 in the form of dry ice that could be captured in vast amounts using NTEC in the future.

Dry ice can be stored if it is highly insulated. We propose that a structure (Figs. 4a & 4b) 540 m x 540 m x 25 m in which compressed dry ice slabs (5 kg to 20 kg weight) will be stacked to a total volume of 500 m x 500 m x 10 m(height). This is surrounded by a gap of 10 m on each side of the square and 5 m on the top, with a thick insulation of 10 m width, 15 m height on all sides. Figs. 4a & 4b show a schematic view of the horizontal and vertical sections of the storage structure. On the top of the structure there is a 5 m air gap on top of which there is the 5 m thick insulation (Fig.4b). The insulation is made of 5 cm to 10 cm (thickness) x 2 m x 2 m slabs of Styrofoam (heat conductivity, k = 0.033 W/mK) or rigid expanded board of polyurethane (k = 0.025 W/mK) [6,25], sandwiched in between shining smooth aluminum foil. The 10 m thick insulation is made by pressing together such insulating units. One can use more insulating layers of polystyrene (heat conductivity 0.02 W/mK), if needed. A simple calculation of heat transmission shows that the maximum annual sublimation (in closed confine) would be 253 tons (1 ton = 1000 kg) if the outside temperature is 102 F for 12 hrs a day. (Now the structure of 500 m x 500 m x 10 m can contain dry ice of mass ~ 3,750,000 tons). With occasional opening of doors, the losses should not exceed 1500 tons annually, if the insulation is kept as mentioned. Thus, more than 99.9% of dry ice can effectively be stored annually.

Using sunlight, the amount of CO2 released from dry ice can be controlled by adjusting the insulation (5 m thick) of the roof (Fig. 4b).




Fig. 4a: Horizontal cross section of the dry ice storage system

© 2022 Global Journals




Fig. 4b: Vertical cross-sectional view of the dry ice storage system

c) *Recapture of Sublimated Co2 From Dry Ice Refrigeration And Air Conditioning Systems And The Storage Structure*

The sublimated CO2 from dry ice refrigeration and air conditioning systems and the storage structure can be quite pure if the initial small fraction of CO2 which would be mixed with air is flushed out. The sublimated pure CO2 can then be captured if needed for enhanced biodiesel production through accelerated growth of algae or jatropha [7-20] or for alcohol production [23a]. It can also be used for soft drink productions, if needed.

d) *Risks Involved in Dry Ice Refrigeration and Air Conditioning Systems*

The major risk involved in dry ice refrigeration and air conditioning systems would be the leakage of CO2 inside MB from the dry ice in BRW (Figs. 3a & 3b). This can be prevented by having sensors inside MB and in the tubes that convey cool air from MB to the main house. If leakage is detected then repairs can be made. The other risk is the leakage of CO2 out of the dry ice AC unit and a high concentration of CO2 in its vicinity. We assume that it will be dispersed into air with time.

e) *Environmental Impact of the Future Dry Ice Air Conditioning*

The total number of housing units in the USA in 2018 was 138 million. Assuming 87% of these have ACs, based on results given in section III.2, the carbon savings in a hot summer month would be $138x0.87x892x10^6$kg = 107 million tons if power is generated by coal, and 23 million tons if power is generated by natural gas. Moreover, there will be savings of ATCs. Thus, dry ice AC would, in the future, substantially contribute towards a clean environment and the mitigation of climate change.

IV. Conclusions

Rigorous theoretical research with a case study (power generation in the UK in 2010) shows in patented technology that it is possible to capture CO2 at a cost - $14.0 to $23 per ton in the form of liquefied CO2 or dry ice, using the new technology, NTEC (Tables A & Table B). Considering all the benefits that the technology will yield, including the revenues that the captured products will bring, the net captured cost becomes either zero or negative. The negative dollar value (Table A) means that the carbon capture can turn out to be profitable without the sale of any captured products.

The new proposed dry ice AC system that can use the abundantly available dry ice with NTEC shows great advantage over conventional AC system. A case study of a 256 sq. m. house reveals that the system can save consumers $147 per month and carbon saving of at least 874 kg and 114 kg in a hot summer month, if the AC is run by electricity generated by coal and natural gas respectively.

© 2022 Global Journals

Thus, such dry ice (solidified CO2) can be used in air conditioning with substantial cost and carbon savings if the industrial carbon emission is captured using the new technology, NTEC. This would help further achieve the objective of climate mitigation and reduce global warming.

Acknowledgement

The authors are grateful to Patricia Rubins for going through the manuscript meticulously and suggesting corrections and improvements.

References Références Referencias

1. Air conditioning accounts for about 12% of U.S. home energy expenditures, Today In Energy, U.S. Energy Information And Administration, https://www.eia.gov/todayinenergy/detail.php?id=36692
2. PickHvac Cooling and Heating Guide…. https://www.pickhvac.com/faq/ac-size/
3. How Much Does it Cost to Run an Air Conditioner? [https://asm-air.com/airconditioning/much cost-run-air-conditioner/].
4. Dry Ice Delivered - https://www.dryicedelivered.com/Product-8/Dry_Ice_Pellets
5. Dilip K. De and Idowu Oduniyi – US patent application 15915007, with provisional patent application No. No.62593828 dated Dec. 1st 2017. US patent Publication No. US-2019-0170436- A1 dated June 6, 2019. References there in. US Patent No. 10670334 B2, June 2, 2020.
6. Global Trends and Pattern in Carbon Mitigation, 1st Edition (2013), Dr. Clifford Jones, Booboon Publisher, P.16-19. Global Trends and Pattern in Carbon Mitigation, 1st Edition (2013), Dr. Clifford Jones, Booboon Publisher, P.16-19.
7. Akash Kumar Modi et al., A Review on Air Preheater Elements Design and Testing, Mechanics, Materials Science & Engineering, https://www.researchgate.net/publication/330101499_A_Review_on_Air_Preheater_Elements_ Design_and_Testing
8. Thermal insulation materials, technical characteristics and selection criteria- http://www.fao.org/3/y5013e/y5013e08.htm
9. Daniel R. Taub Effects of Rising Atmospheric Concentrations of Carbon Dioxide on Plants © 2010 Nature Education (2010) *Nature Education Knowledge* 3(10): 21. https://www.nature.com/scitable/knowledge/library/effects-of-rising-atmospheric concentrations-of-carbon-13254108.
10. Ainsworth, E. A. Rice production in a changing climate: a meta-analysis of responses to elevated carbon dioxide and elevated ozone concentration. *Global Change Biology* 14, 1642-1650 (2008).
11. Sherry Seethaler, UCSD Study Reveals How Plants Respond to Elevated Carbon Dioxide, https://ucsdnews.ucsd.edu/archive/newsrel/science/sCO2plants.asp
12. *Tim Radford,* C L I M A T E , Ask the Experts: Does Rising CO2 Benefit Plants? Annie Sneed on January 23, 2018, Scientific American, https://www.scientific-american.com/article/askthe-experts-does-rising-co2-benefit-plants1/
13. Study Finds Plant Growth Surges as CO2 Levels Rise, CLIAMTE CENTRAL, https://www.climate-central.org/news/study-finds-plant-growth-surges-as-co2-levels-rise 16094
14. Stuart Thompson, The Conversation, Will rising carbon dioxide levels really boost plant growth? https://phys.org/news/2018-04-carbon-dioxide-boost-plantgrowth.html
15. Gao, K., Aruga, Y., Asada, K., Ishihara, T., Akano, T. and Kiyohara, M. 1991. Enhanced growth of the red alga *Porphyra yezoensis* Ueda in high CO2 concentrations. *Journal of Applied Psycology* 3: 355-362.
16. Algae – Summary, CO2 Science,http://www.co2science.org/subject/a/summaries/algae.php Algae Biodiesel Engineering: Extracting Oil from Algae, http://science.howstuffworks.com/environmental/green-science/algae-biodiesel2.htm [15a] Ihsanullah, Sumaira Shah, Muhammad Ayaz, Iftikhar Ahmed, Murad Ali, Naveed Ahmad and Irshad Ahmad, Production of Biodiesel from Algae, JOURNAL OF PURE AND APPLIED MICROBIOLOGY, March 2015. Vol. 9(1), p. 79-85. https://doi.org/10.1016/j.hjb.2017.10.003
17. Algae Biodiesel Engineering: Extracting Oil from Algae, http://science.howstuffworks.com/environmental/green-science/algae-biodiesel2.htm
18. Suliman Khan , Rabeea Siddique , Wasim Sajjad, Ghulam Nabi , Khizar Mian Hayat, Pengfei Duan , Lunguang Yao, Biodiesel Production From Algae to Overcome the Energy Crisis HAYATI Journal of Biosciences, Volume 24, Issue 4, October 2017, Pages 163-167 https://doi.org/10.1016/j.hjb.2017.10.003
19. Surprising findings on hydrogen production in green algae, *Date:*April 15, 2013, *Source:* Uppsala Universitet, https://www.sciencedaily.com/releases/2013/04/130415182430.htm
20. Archita Sharma and Shailendra Kumar Arya, Hydrogen from algal biomass: A review of production process Biotechnol Rep (Amst). 2017 Sep; 15: 63–69., Published online 2017 Jun 14. doi: 10.1016/j.btre.2017.06.001.
21. Kumar S, Chaitanya BS, Ghatty S, Reddy AR, Growth, reproductive phenology and yield responses of a potential biofuel plant, Jatropha curcas grown under projected 2050 levels of elevated CO2. Physiol Plant. 2014 Nov;152(3):501-19. doi: 10.1111/ppl.12195. Epub 2014 May 22.

© 2022 Global Journals

22. Siddharth Jain M.P. Sharma, Biodiesel production from *Jatropha curcas* oil Renewable and Sustainable Energy Reviews, Volume 14, Issue 9, December 2010, Pages 3140-3147, https://doi.org/10.1016/j.rser.2010.07.047.
23. Anderson S. (2017). Risk, Liability, and Economic Issues with Long-Term CO2 Storage—A Review *Natural Resources Research*, *26*, 89–112.
24. Barriers to overcome in implementation of CO2 capture and storage in diffused oil and gas fields-Report Number PH3/22, February 2000- IEA Greenhouse R&D programme https://ieaghg.org/docs/General_Docs/Reports/PH3_22%20Storage%20in%20oil%20and%20gas %20fields.pdf
25. a. Next level nano Science in Ethanol PRODUCER MAGAZINE- By Lisa Gibson | February 15, 2018. Technology Innovation Program-2017 – Oak Ridge National Labpratory, U.S. Department of Energy, https://www.ornl.gov/sites/default/files/ 2019- 02/17-G00973_Tech_Innov_Program_fnl. pdf.
26. b. Technology Innovation Program 2017 -Oak Ridge National Laboratory, Energy. https://www.ornl.gov/sites/default/files/2019-02/17-G00973_Tech_Innov_Program_fnl.pdf
27. Larry Baxter, Andrew Baxter, Chris Bence, David Frankman, Chris Hoeger, Aaron Sayre, Kyler Stitt, and Skyler Chamberlain, "Cryogenic carbon capture" in "CO2 Summit II: Technologies and Opportunities", Holly Krutka, Tri-State Generation & Transmission Association Inc. Frank Zhu, UOP/Honeywell Eds, ECI Symposium Series, (2016). https://dc.engconfintl.org/co2_summit2/12.
28. A Toleuova, S Mackintosh, M Maroto-Valer, A Finn-Modelling and Optimisation of Cryogenic Capture of Carbon Dioxide - 2nd OxyFuel Combustion Conference Queensland, Australia September 12th -16th, 2011
29. Thermal insulation materials made of rigid polyurethane foam (PUR/PIR), Report N°1 (October 06), BING, Federation of Rigid Polyurethane Foam Associations.
30. A Process for Capturing CO2 from the Atmosphere David W. Keith, Geoffrey Holmes, David St. Angelo, and Kenton Heidel, Joule 2, 1–22, August 15, 2018.
31. Mahdi Fasihi, Olga Efimova, Christian Breyer Techno-economic assessment of CO_2 direct air capture plants, Journal of Cleaner Production, Volume 224, 1 July 2019, Pages 957-980. https://doi.org/10.1016/j.jclepro.2019.03.086
32. K. E. Zanganeh, A. Shafeen, and C. Salvador, "CO2 capture and development of an advanced pilot-scale cryogenic separation and compression unit," *Energy Procedia*, vol. 1, pp. 247–252, 2009
33. G. Xu, L. Li, Y. Yang, L. Tian, T. Liu, and K. Zhang, "A novel CO2 cryogenic liquefaction and separation system," *Energy*, vol. 42, pp. 522–529, 2012.
34. C.-F. Song, Y. Kitamura, S.-H. Li, and K. Ogasawara, "Design of a cryogenic CO2 capture system based on Stirling coolers," *International Journal of Greenhouse Gas Control*, vol. 7, pp. 107–114, 2012.
35. M. J. Tuinier, M. van Sint Annaland, and J. A. M. Kuipers, "A novel process for cryogenic CO2 capture using dynamically operated packed beds-An experimental and numerical study," *International Journal of Greenhouse Gas Control*, vol. 5, no. 4, pp. 694–701, 2011.
36. Paul Breeze, Combined Heat and Power, Book 2018, Academic Press, ISBN
37. Edward S. Rubin,∗, John E. Davison, Howard J. Herzog, International Journal of Greenhouse Gas Control, The cost of CO2 capture and storage, Vol: 40(2015) 378-400.
38. Barry, Larry L. U.S. Patent 9410736, August 9, 2016; US 2013/0139543, June 6, 2013

Appendix A

Estimation Of The Cost Of Running A Dry Ice Air Conditioner Using NTEC For Capturing Industrial Emissions In A Case Study

To estimate the mass of dry ice needed for the air conditioning of a house we proceed as follows:

1. A house of inside area 256 sq. m. and internal height 4 m is considered. The volume is 1024 m^3. The density of air is 1.225 kg/m^3. Thus, the mass of the air in the house is 1254 kg. The specific heat of air is ~1 kJ/ kg.°C.
2. We assume that the outside temperature is 102°F. So, the total amount of heat to be taken out of the room on the first day is $\Delta Q1$ = 1254 kg x 1 kJ/kg. °C x 17.78°C = 22.3 MJ. We now assume that the house is well insulated and the furniture and equipment necessitates additional cooling of 20% of this heat reduction. Thus, total heat reduction on the first day is $\Delta Q2$ = 26.8 MJ.
3. We assume that the outside temperature remains at 85°F at night. Every night 20% of the air inside is replaced by fresh outside air. The amount of heat brought into the house from outside is $\Delta Q3$ = 52 MJ in a hot summer month.
4. We suppose that the house of area 256 sq. m. (total floor area) has four sides each of length 16 m and height 4 m (~13 ft) and has effective wall thickness of 75 cm with effective thermal conductivity of that of rigid expanded board of polyurethane (0.025 W/mK at polyurethane density 30 kg/m^3) [25]. We suppose that the ceiling (area 256 sq. m.) has an effective thickness of 1.5 m insulation. We assume that the outside temperature stays effectively at 102°F for 12 hrs in the daytime and at 85°F for 12 hrs at night and a central inner space of dimensions 12mx12mx3m stays at 70°F for 24

© 2022 Global Journals

hours a day. In such a situation the total heat flow into the house is ΔQ4 = 381 MJ in a hot summer month. This calculation is done by calculating the temperature at the inner wall and roof during equilibrium heat flow in the daytime and at night and then using a simple heat flow equation and calculating the total heat flow for the month through the walls and the roof during the day and during the night.

5. The additional heat penetrating the dry ice box (Fig. 3a) is ΔQ5 = 32 MJ. This is calculated considering the total surface area of the dry ice slabs (5x1.3^2 m^{2}in the example considered). This will cause additional loss (over that due to (iii) & (iv) above) of dry ice by sublimation.
6. Thus, after the first day of cooling, the total heat flowing into the house (maintained at 70°F 24 hrs a day for 30 days) isΔQ = ΔQ3 + Δ Q4 + ΔQ5 = 52 + 381 + 32 = 465 MJ for a hot summer month.
7. This heat would be removed by sublimation of dry ice which has latent heat of evaporation 578 kJ/kg at –78°C. Now its temperature will be raised from –78°C to 70°F (=21.1°C). Thus, the temperature change is 99.1°C. The specific heat of CO2 is 0.9 kJ/kg.°C. Thus, the total heat that can be removed by sublimation of dry ice is ΔH = 578 + 99.1x0.9 = 667 kJ/kg.
8. Thus, the total dry ice that would be needed for cooling the house for the month is ΔQ/ΔH = 465 MJ/0.667 MJ/kg = 697 kg = ~700 kg.
9. Considering that with NTEC dry ice can be available to residential customers at $80 per ton (1000 kg), the total cost of dry ice with NTEC will be ~$56 for the month. Thus, dry ice AC, which is not affordable with current technology, can be easily affordable with NTEC.
10. An analysis of the net energy usage in a similar situation (running 12 hrs a day effectively) using conventional AC shows that a 5-ton AC is needed. With a 5 star AC (EER = 3.5) the power consumption for the month is 5kWx12h/dayx30days = 1800 kWh. With 12 cents per kWh in Texas this will cost the consumer $216 for the hot summer month [X] [XX] [XXX].
11. Thus, we see that the dry ice AC can save $216 – $56 = $160 in a hot summer month for a house of 256 sq. m.
12. As said before, conventional AC would require the generation of 1800 kWh of energy. CO2 emissions are 0.94 kg and 0.55 kg per kWh from coal power plants and natural gas power plants respectively. Thus, the carbon saving by the proposed dry ice AC, in generating the power for the conventional AC (5-ton) in a hot summer month, would be 1800x0.94 – 700 = 992 kg if coal is used, and 1800x0.55 – 700 = 290 kg if natural gas is used. This saving in carbon emission assumes that the sublimated CO2 is not captured back.
13. If the effective wall and roof insulations are 50 cm and 1 m thick respectively with the same materials as mentioned earlier, then the total heat flow through the walls and the roof into the house in the month is ΔQ4 = 1.5x381 MJ = 572 MJ. The additional dry ice to be sublimated is 286 kg, to keep the house at 70°F for the month. The additional cost is $23. The net consumer savings would then be $160 - $23 = $137. The total carbon emission savings would be 992 - 286 = 706 kg, if the power is generated by coal. Thus, the dry ice AC would save considerable consumer cost and carbon emission.
14. If the effective wall and roof insulations are 50 cm and 1 m thick respectively with the same materials as mentioned earlier, then the total heat flow through the walls and the roof into the house in the month isΔQ4 = 1.5x381 MJ = 572 MJ. The additional dry ice to be sublimated is 286 kg, to keep the house at 70°F for the month. The additional cost is $23. The net consumer savings would then be $160 - $23 = $137. The total carbon emission savings would be 992 - 286 = 706 kg, if the power is generated by coal. Thus, the dry ice AC would save considerable consumer cost and carbon emission.
15. https://www.quora.com/How-much-electricity-units-is-used-by-1-ton-split-AC
16. https://letsavelectricity.com/power-consumption-of-ac-how-much-power-does-an-ac-use/
17. https://asm-air.com/airconditioning/what-size-central-air conditioner-for-my-house/

Appendix B

a) Determination of The Size of the Box Mb (Fig. 3b)

We assume the box MB (Fig.3) to be a cube of side a (meters) and the area A of the metal plate is A = a^2. Let us assume that on the first day we want to cool the entire house by 16°F in 3 hours when the air inside (mass 1254 kg) is at 102°F. The specific heat of air is ~1 kJ/kg.°C. The rate of heat reduction (section (ii) of Appendix A) is 26800x(16/32)/(3600x3) = 1.24 kJ/s on the first day. Then the maximum heat flow from the walls and roof is 256 (102-86)(5/9)(0.025){1/0.75) + (1/1.5)} = 0.11 kJ/s, , assuming that the air inside is at 86°F during the 3 hours and the air outside is at 102°F. This figure (0.11 kJ/s) is somewhat higher than what one would get with rigorous calculations. Nevertheless it will better help the design of the box MB. So, the required heat flow rate out of the house is 1.35 kJ/s so that the house cools to 86°F from 102°F in 3 hours on the first day. This should be the cooling rate of the air inside the box MB. The accuracy of this model of the cooling rate depends on three factors:

© 2022 Global Journals

We assume the box MB (Fig.3) to be a cube of side a (meters) and the area of the metal plate is $A = a^2$. To find the maximum rate of cooling needed, let us assume that on the first day we want to cool the entire house by 16°F in 3 hours when the air inside (mass 1254 kg) is at 102°F.

1. The conduction from hot air to dry ice through the metal in the box MB (Fig. 3) as hot air from the house is continuously pumped in. Calculation gives the heat conduction rate of 0.02x(38.9+78.5) x6A/(a/2) = 0.028a kJ/s.
2. We assume that as the hot air from the house is brought into the box, the center of the box is at 102°F, while the metal plate surface is at -78.5°C, since it is in contact with dry ice. The maximum radiation from the metal surface to the middle of the box is $\sigma((273 + 38.9)^4 - (273 - 78.5)^4)x6A = 2.73a^2$kJ/s ($\sigma$ = Stefan Boltzmann constant = $5.67x10^{-8}$ W/m^2.K^4; the factor 6 comes from the 6 faces of the box) We assume that the volume pump rate of air in the box is a^3/s. Then balancing the heat flow equation we get: $0.028a + 2.73a^2 = 1.35$. Solving this we get a = 0.70 m. We take the metal plate size as 0.7 m as mentioned earlier. Thus, if the air in the box MB (mass = 0.42 kg) is replaced every second (i.e. flow rate = 0.42 kg/s) then the entire house will cool in 3 hrs from 102°F to 86°F. Here we assume that the dry ice slabs are always kept in contact with the metal walls of the metal box with the use of a spring as mentioned earlier. The flow rate can be adjusted if needed to maintain the time of cooling at approximately 3 hours if needed.
3. Heat transfer coefficient as a function of air flow velocity witnin the box: While this factor is under modeling, we estimate that the effective time of cooling the house by 16°F would be somewhat less than 3 hrs on the first day. This is a pretty good rate of cooling. When the air mass attains 70°F, approximately after 6 hours, then to maintain this temperature while the outside is at 102°F, the cool air flow rate would be 0.076 kg/s. The temperature controller can be made to adjust the fan rates automatically.




Fig. 1: Schematic diagram of the equipment based on NTEC to capture CO2 and the toxic components of the FG from power plants most cost-effectively with very high energy efficiency (244 MJ per ton of CO2 from a coal power plant and -237 MJ per ton of CO2 from a natural gas power plant. The US patent No. 10670334 B2, with 18 sub-claims for the above equipment, and 19 process claims have been issued on June 2, 2020.

Appendix C: References for Introduction 1.1.1 to 1.1.2.

1. L. Moretti AND C.S. Jones, Advanced Emissions Control Technologies for Coal-Fired Power Plants-Technical Paper, BR-1886-*Babcock & Wilcox, Power Generation Group, Inc., Barberton, Ohio, U.S.A., Presented to: Power-Gen Asia, Date: October 3-5, 2012, Location: Bangkok, Thailand*.

© 2022 Global Journals

1a] Mohammad Songolzadeh, Mansooreh Soleimani, Maryam Takht Ravanchi, and Reza Songolzadeh , Carbon Dioxide Separation from Flue Gases: A Technological Review Emphasizing Reduction in Greenhouse Gas Emissions, The Scientific World Journal, Volume 2014 (2014), Article ID 828131, 34 pages, http://dx.doi.org/10.1155/2014/828131

[1b] Burt S S, Baxter A, Bence C, Baxter L L. Cryogenic CO2 capture for improved efficiency at reduced cost. In: Proceedings of the AICHE 2010 annual meeting; November7–12,2010.

[1c] M. Lucquiaud and J. Gibbins, "On the integration of CO2 capture with coal-fired power plants: a methodology to assess and optimise solvent-based post-combustion capture systems," Chemical Engineering Research and Design, vol. 89, no. 9, pp. 1553–1571, 2011. View at Publisher · View at Google Scholar · View at Scopus

[1d] Katie Fehrenbacher, June 29, 2017, carbon Capture Suffers a Huge Setback as Kemper Plant Suspends Work, https://www.greentechmedia.com/articles/read/carbon-capture suffers-a-huge-setback-as-kemper-plant-suspends-work#g

[1e] World's First Commercial CO2 Capture Plant Goes Live, *By Bobby Magill, Published: May 31st, 2017. http://www.climatecentral.org/news/first-commercial-co2-capture-plant-live-21494.*

Researching and reporting the science and impacts of climate change. http://www.climatecentral.org /news/first-commercial-co2-capture-plant-live-21494

1[f] Jeremy van Loon | December 9, 2014 -High Cost Hinders Progress of Carbon Capture As Climate-Change Fix, https://www.insurancejournal.com/news/national/2014/12/09/349295.htm [1g] 4 OCTOBER 2018, The cost of carbon capture: is it worth incorporating into the energy mix? https://www.insurancejournal.com/news/national/2014/12/09/349295.htm

2. Brian H. Bowen, Marty W. Irwin Basic Mercury Data & Coal Fired Power Plants CCTR Indiana Center for Coal Technology Research March 2007 CCTR Basic Facts File #2 Brian H. Bowen, Marty W. Irwin The Energy Center at Discovery Park Purdue University CCTR, Potter Center, 500 Central Drive West Lafayette, IN 47907-2022

2a. Health, Environmental Effects, the Control of Emission from Power Plants and the Need for a New Emission Capture Technology. To cite this article: D K De, U I Ikono and S O Akinmeji J. Phys.: Conf. Ser. 1072, 012019 (2018).

2b. Public Health Statement for Sulfur Trioxide and Sulfuric Acid, December 1998, ASDTR(Agency for Toxic Substance and Disease registry), CAS#: Sulfur Trioxide 7446-11- 9; Sulfuric Acid 7664-93-9, https://www.atsdr.cdc.gov/phs/phs.asp?id=254&tid=47

2c. R. W. Gerstle, S. T. Cuffe, A. A. Orning and C. H. Schwartz, Journal of the Air Pollution Control Association, 15:2, 59-64, DOI: 10.1080/00022470.1965.10468337 https://doi.org/10.1080/00022470.1965.10468337

2d. *Eggleton, R. A. , Eggleton, Tony (2013). A Short Introduction to Climate Change. Cambridge University Press. p. 52. https://books.google.com/books/about/A_Short_Introduction_to_Climate_Change.html?id= ofxDAQAACAAJ*

2e. Sulfur Dioxide (SO2) Pollution, United States Environmental Protection Agency, https://www.epa.gov/so2-pollution/sulfur-dioxide-basics#effects

2f. N_2O-Greenhouse Gases and Global Warming Potential Values Excerpt; Inventory of U.S. Greenhouse Gas Emissions and Sinks: 1990 - 2000, U.S. Environmental Protection Agency, Office of Atmospheric Programs, EPA 430-R-02- 003, April 2002.

2g. Consequences of Carbon Emissions for Humans- http://education.seattlepi.com/consequences carbon-emissions-humans-4138.html

3. The Cost of Mercury Removal in an IGCC Plant M.D. Rutkowski, M.G. Klett, R.C. Maxwell, October 1, 2002 Washington, D.C., Gasification Technologies Public Policy Workshop, , Journal of the Air & Waste Management Association, 60:3, 302-315, DOI: 10.3155/1047-3289.60.3.302
4. Thief Process for Mercury Removal from Flue Gas Evan J. Granite*, Mark C. Freeman, Richard A. Hargis, William J. O'Dowd, and Henry W. Pennline, Journal of environmental management 2006 ; DOI:10.1016/j.jenvman.2006.06.022
5. Dilip K. De and Idowu Oduniyi – Proposal for 100% Renewable Energy Transformation Submitted to International Solar Energy Society & Elsevier – Renewable Energy Transformation Challenge- Abu Dhabi 2017. US Patent Application No. 15915007, with Provisional Patent Application No. 62593828 dated Dec. 1st 2017. US Patent Publication No. US-2019-0170436- A1 dated June 6, 2019 and US patent No. 10670334 June 2, 2020. References therein.
6. K.A. Kelly, M.C. McManus, G.P. Hammond An energy and carbon life cycle assessment of 356 industrial CHP (combined heat and power) in the context of a low carbon UK, Energy 77, (2014) 357 812e821.
7. A Global Perspective on Sulfur Oxide Controls in Coal-Fired Power Plants and Cardiovascular Disease, Cheng-Kuan Lin, Ro-Ting Lin, Pi-Cheng Chen, Pu Wang, Nathalie De Marcellis Warin, Corwin Zigler & David C. Christiani, *Scientific Reports* volume 8, Article number: 2611 (2018)
8. Public Health Statement for Sulfur Trioxide and Sulfuric Acid, December 1998, ASDTR(Agency for Toxic Substance and Disease registry), CAS#:

© 2022 Global Journals

Sulfur Trioxide 7446-11-9; Sulfuric Acid 7664-93-9, Brian H. Bowen, Marty W. Irwin Basic Mercury Data & Coal Fired Power Plants CCTR Indiana Center for Coal Technology Research March 2007 CCTR Basic Facts File #2 Brian H. Bowen, Marty W. Irwin The Energy Center at Discovery Park Purdue University CCTR, Potter Center, 500 Central Drive West Lafayette, IN 47907-2022 http://www.purdue.edu/dp/energy/CCTR/ Email: cctr@ecn.purdue.edu. https://purdue.edu/discoverypark/energy/assets/pdfs/cctr/outreach/Basics2-Mercury-Mar07.pdf

9. Mercury emissions control from coal fired thermal power plants in India: Critical review & suggested Policy measures V K Rai , Chief Manager (Civil), Mahanadi Coalfields Limited. . Dr N S Raman , Dy Director & Principal Scientist, NEERI, Nagpur Dr S K Choudhary, Professor, Mechanical Engineering Department, KDK College of Engineering, International Journal of Engineering Research & Technology (IJERT) Vol. 2 Issue 11, November – 2013.
10. Ravi Srivastava, Principal Investigator, FINAL TECHNICAL REPORT September 1, 2002, through August 31, 2003 Project Title: EVALUATION OF SCR CATALYSTS FOR COMBINED CONTROL OF NOX AND MERCURY ICCI Project Number: 02- 1/2.2A-1, U.S. EPA
11. L. Moretti AND C.S. Jones, Advanced Emissions Control Technologies for Coal-Fired Power Plants-Technical Paper, BR-1886-*Babcock & Wilcox, Power Generation Group, Inc.*, *Barberton, Ohio, U.S.A.*, *Presented to: Power-Gen Asia, Date: October 3-5, 2012,Location:Bangkok, Thailand*.
12. Brian H. Bowen, Marty W. Irwin Basic Mercury Data & Coal Fired Power Plants CCTR Indiana Center for Coal Technology Research March 2007 CCTR Basic Facts File #2 Brian H. Bowen, Marty W. Irwin The Energy Center at Discovery Park Purdue University CCTR, Potter Center, 500 Central Drive West Lafayette, IN 47907-2022.
13. The Cost of Mercury Removal in an IGCC Plant M.D. Rutkowski, M.G. Klett, R.C. Maxwell, October 1, 2002 Washington, D.C., Gasification Technologies Public Policy Workshop, , Journal of the Air & Waste Management Association, 60:3, 302-315, DOI: 10.3155/1047-3289.60.3.302
14. Thief Process for Mercury Removal from Flue Gas Evan J. Granite*, Mark C. Freeman, Richard A. Hargis, William J. O'Dowd, and Henry W. Pennline, Journal of environmental management 2006 . DOI:10.1016/j.jenvman.2006.06.022
15. K.A. Kelly, M.C. McManus, G.P. Hammond An energy and carbon life cycle assessment of 356 industrial CHP (combined heat and power) in the context of a low carbon UK, Energy 77, (2014) 357 812e821.
16. A Global Perspective on Sulfur Oxide Controls in Coal-Fired Power Plants and Cardiovascular Disease, Cheng-Kuan Lin, Ro-Ting Lin, Pi-Cheng Chen, Pu Wang, Nathalie De Marcellis Warin, Corwin Zigler & David C. Christiani, *Scientific Reports*volume 8, Article number: 2611 (2018)
17. Public Health Statement for Sulfur Trioxide and Sulfuric Acid, December 1998, ASDTR(Agency for Toxic Substance and Disease registry), CAS#: Sulfur Trioxide 7446-11-9; Sulfuric Acid 7664-93-9, https://www.atsdr.cdc.gov/phs/phs.asp?id=254&tid=47
18. Brian H. Bowen, Marty W. Irwin Basic Mercury Data & Coal Fired Power Plants CCTR Indiana Center for Coal Technology Research March 2007 CCTR Basic Facts File #2 Brian H. Bowen, Marty W. Irwin The Energy Center at Discovery Park Purdue University CCTR, Potter Center, 500 Central Drive West Lafayette, IN 47907-2022 http://www.purdue.edu/dp/energy/CCTR/ Email: cctr@ecn.purdue.edu. https://purdue.edu/discoverypark/energy/assets/pdfs/cctr/outreach/Basics2-Mercury-Mar07.pdf
19. Mercury emissions control from coal fired thermal power plants in India: Critical review & suggested Policy measures V K Rai , Chief Manager (Civil), Mahanadi Coalfields Limited. . Dr N S Raman , Dy Director & Principal Scientist, NEERI, Nagpur Dr S K Choudhary , Professor, Mechanical Engineering Department, KDK College of Engineering, International Journal of Engineering Research & Technology (IJERT) Vol. 2 Issue 11, November – 2013.
20. Ravi K. Srivastava and Chun Wai Lee, Evaluation of SCR Catalysts for Combined Control of NOX and Mercury, EPA-600/R-04/130, September 2004.
21. N_2O-GREENHOUSE GASES AND GLOBAL WARMING POTENTIAL VALUES EXCERPT; Inventory of U.S. Greenhouse Gas Emissions and Sinks: 1990 - 2000, U.S. Environmental Protection Agency, Office of Atmospheric Programs, EPA 430-R-02- 003, April 2002.
22. *Eggleton, R. A. Eggleton, Tony (2013).* A Short Introduction to Climate Change*. Cambridge University Press. p. 52.*
23. Jo Husebye, Amy L. Brunsvold, Simon Roussanaly, and Xiangping Zhang, Techno economic evaluation of amine based CO2 capture: impact of CO2 concentration and steam supply, Energy Procedia 23 (2012) 381 – 390.
24. Stefania Osk Gardarsdottir,* Edoardo De Lena, Matteo Romano, Simon Roussanaly, Mari Voldsund, José-Francisco Pérez-Calvo, David Berstad, Chao Fu, Rahul Anantharaman, Daniel Sutter, Matteo Gazzani, Marco Mazzotti and Giovanni Cinti- Comparison of Technologies for CO2 Capture from Cement Production—Part 2:

© 2022 Global Journals

Cost Analysis Energies 2019, 12, 542; doi:10.3390/en12030542.

25. Anand B. Rao, Details of A Technical, Economic and Environmental Assessment of Aminebased CO2 Capture Technology for Power Plant Greenhouse Gas Control, Report Submitted October, 2002, Work Performed Under Contract No.: DE-FC26-00NT40935,
26. Mohammad Songolzadeh,[1] Mansooreh Soleimani,[1] Maryam Takht Ravanchi,[2]and Reza Songolzadeh' Carbon Dioxide Separation from Flue Gases: A Technological Review Emphasizing Reduction in Greenhouse Gas Emissions, The Scientific World Journal, Volume 2014 (2014), Article ID 828131, 34 pages,
27. Allan Hart and Nimalan Gnanendran, Cryogenic CO2 Capture in Natural Gas Energy Procedia 00 (2008) 000–00.
28. B. Shimekit and H. Mukhtar, "Natural gas purification technologies-major advances for CO2 separation and future directions," in Advances in Natural Gas Technology, A. M. Hamid, Ed., pp. 235–270, InTech, China, 2012.
29. M. T. Ravanchi, S. Sahebdelfar, and F. T. Zangeneh, "Carbon dioxide sequestration in petrochemical industries with the aim of reduction in greenhouse gas emissions," Frontiers of Chemical Engineering in China, vol. 5, no. 2, pp. 173–178, 2011.
30. R. P. Lively, W. J. Koros, and J. R. Johnson, "Enhanced cryogenic CO2 capture using dynamically operated low-cost fiber beds," Chemical Engineering Science, vol. 71, pp. 97–103, 2012.
31. Christine Shearer, Robert Fofrich, Steven J. Davis, Future CO2 emissions and electricity generation from proposed coal-fired power plants in India, Earth's Future, Volume 5, p.408-416, (2017). DOI: 10.1002/2017EF000542. http://onlinelibrary.wiley.com/doi/10.1002/2017EF000542/full
32. Ravnum S[1], Rundén-Pran E[1], Fjellsbø LM[1], Dusinska M[2], Human health risk assessment of nitrosamines and nitramines for potential application in CO2 capture, Regul Toxicol Pharmacol. 2014 Jul;69(2):250-5. doi: 10.1016/j.yrtph.2014.04.002. Epub 2014 Apr 18.
33. David Roberts, Sucking carbon out of the air won't solve climate change Updated Jul 16, 2018, 2:14pm EDT,
34. Furukawa H et al. *Ultrahigh porosity in metal-organic frameworks*. Science. 2010 Jul 23;329(5990):424-8. doi: 10.1126/science. 1192160. Epub 2010 Jul 1.
35. Brian H Bowen, Marty W Irwin. *Basic mercury data & coal fired power plants CCTR Indiana centre for coal technology research March 2007 CCTR basic facts file #2*
36. EPA technical bulleting. *NOx - How and why they are controlled*. EPA-456/F-99-006R November 1999.
37. IUPAC. *Compendium of chemical terminology, 2nd ed. (the "gold book") (1997)*. Online corrected version: (2006–) electrostatic precipitators.
38. *Air pollution control technology fact sheet*, EPA-452/F-03-031 https://www3.epa.gov/ttncatc1/dir1/fsncr.pdf
39. NOL-TEC system. *Bag-house/Fabric Filters* http://www.nol-tec.com/fabric-filters.html
40. 17a Tri-Mer Corporation. *Venturi technology, High-Energy Venturi Gas Scrubbers, Technology Leader Multi-Pollutant Control*: http://www.tri-mer.com/venturi-scrubbers.html.
41. Pollution systems. *Industrial air solutions*. http://www.pollutionsystems.com/particulate-scrubbers-venturi-scrubbers.html
42. *Air pollution control technology fact sheet*. EPA-452-03-031 https://www3.epa.gov/ttncatc1/dir1/fsncr.pdf
43. Paul S. Nolan, Babcock & Wilcox Company Barberton, Ohio, USA. *Flue gas desulfurization technologies for coal-fired power plants*. Presented by Michael X. Jiang, Coal-Tech 2000 International Conference. November 13-14, 2000 Jakarta, Indonesia
44. *Spray dryer absorber*. Babcock and Wilcox http://www.babcock.com/products/Pages/Spray-Dry-Absorber-(Dry-Scrubber).aspx
45. *Circulating dry scrubber (CDS) technology*. Babcock and Wilcox. http://www.babcock.com/products/circulating-dry-scrubber-cds

45a. "*Introduction to Carbon Capture and Storage - Carbon storage and ocean acidification activity*". *Commonwealth Scientific and Industrial Research Organisation (CSIRO) and the Global CCS Institute. Archived from the original on 2012-12-08. Retrieved 2013-07-03.*

45b. Bui M, Adjiman CS, Bardow A, Anthony EJ, Boston A, Brown S, Fennell PS, Fuss S, Galindo A, Hackett LA, Hallett JP. Carbon capture and storage (CCS): the way forward. Energy & Environmental Science. 2018;11(5):1062-176.

45c. Postnote-Parliamentary Office of Science & Technology, June 2009, No.335- Carbon capture, and transport and storage.mm.

45d. BECCS deployment: a reality check MATHILDE FAJARDY, DR. ALEXANDRE KÖBERLE, DR. NIALL MAC DOWELL, DR. ANDREA FANTUZZI, Grantham Institute Briefing paper No 28 January 2019, Imperial College London.

45e. Amir Erfani, Daeed Hassan Boroojerdi and A. Dehghani, Simulation of an operational amine based CO2 removal plant as an example of CO2 capture at coal-fired power plants, December 2014, Petroleum and Coal 57(1):85-92.

45f. Air pollution impacts from carbon capture and storage (CCS), EEA Technical report No 14/2011

© 2022 Global Journals

45g. Carbon capture and storage (CCS), Alok Jha, *green technology correspondent,* Fri 5 Sep 2008 12.16 EDT First published on Fri 5 Sep 2008 12.16 EDT. https://www.theguardian.com/environment/2008/sep/05/carboncapturestorage.carbonemissions1
46. Dry Sorbent Technology, Air Pollution Control with Dry Sorbent Injection Technology, https://www.ahperformance.com/markets/industrial/dry-sorbent-technology/
47. *Flue gas desulphurisation – trends and opportunities* http://www.modernpowersystems.com/features/featureflue-gas-desulphurisation-trends-and opportunities/ 1 May, 2009.
48. Låg M, Lindeman B, Instanes C, Brunborg G and Schwarze P. *Health effects of amines and their derivatives associated with CO2 capture.* The Norwegian Institute of Public Health, 2011 ISBN 978-82- 8082-462-2
49. Barchas, R. and R. Davis (1992). *The Kerr-McGee/ABB Lummus Crest technology for the recovery of CO2 from stack gases*. Energy Conversion and Management, 33(5-8), pp 333-340
50. Jo Husebye, Amy L Brunsvold , Simon Roussanaly, and Xiangping Zhang. *Techno economic evaluation of amine based CO2 capture: impact of CO2 concentration and steam supply*. Energy Procedia 23 (2012) pp. 381 – 390.
51. Anand B. Rao. *Details of a technical, economic and environmental assessment of amine based CO2 capture technology for power plant greenhouse gas control*. Report Submitted October, 2002, Work performed under Contract No.: DE-FC26-00NT40935,
52. Ravnum S, Rundén-Pran E, Fjellsbø LM and Dusinska M. *Human health risk assessment of nitrosamines and nitramines for potential application in CO2 capture*. Regul Toxicol Pharmacol. July, 2014; 69(2):250-5. doi: 10.1016/j.yrtph.2014.04.002. Epub 2014 Apr 18.
53. Allan Hart and Nimalan Gnanendran. *Cryogenic CO2 Capture in Natural Gas*. Energy Procedia 00 (2008) 000–00
54. Shimekit and H. Mukhtar. *Natural gas purification technologies-major advances for co2 separation and future directions in advances in natural gas technology*, A. M. Hamid, Ed., pp. 235– 270, InTech, China, 2012. View at Google Scholar.
55. M T Ravanchi, S Sahebdelfar, and F T Zangeneh. *Carbon dioxide sequestration in petrochemical industries with the aim of reduction in greenhouse gas emissions*. Frontiers of Chemical Engineering in China, vol. 5, no. 2, pp. 173–178, 2011. View at Publisher · View at Google Scholar· View at Scopus
56. R P Lively, W J Koros, and J R Johnson. *Enhanced cryogenic CO2 capture using dynamically operated low-cost fibre beds*. Chemical Engineering Science, vol. 71, pp. 97–103, 2012. View at Publisher ·View at Google Scholar · View at Scopus
57. Carbon Capture and Storage Development Trends from a Techno-Paradigm Perspective Bobo Zheng and Jiuping Xu. Energies 2014, 7, 5221-5250; doi:10.3390/en7085221.
58. Cost and economic potential, Pradeep Dadhich, James Dooley, Yasumasa Fujii, Olav Hohmeyer, Keywan Riahi, et al., IPCC Special Report on Carbon dioxide Capture and Storage, pp. 340-362
59. Michael C. Stern-Electrochemically-Mediated Amine Regeneration for Carbon Dioxide Separations, Ph.D thesis (MIT) (2013).
60. Kun Yu, William A. Mitch, and Ning Dai, Nitrosamines and Nitramines in Amine-Based Carbon Dioxide Capture Systems: Fundamentals, Engineering Implications, and Knowledge Gaps, *Environ. Sci. Technol.* 2017, 51, 20, 11522–11536, https://doi.org/10.1021/acs.est.7b02597
61. Carbon Capture Is Expensive, January 19th, 2016 by Michael Barnard, Clean Technica

Appendix D [from US Patent- Dilip K. De and Idowu Oduniyi- Patent No. 10670334, B2, June 2, 2020; Ref.5]

Brief Description of Key Principles And Methods to Produce A Vast Amount Of Dry Ice from Industrial Flue Gas At A Very Low Or No Cost.

The key principles of the highly cost-effective industrial emission capture technology to capture carbon are described below in reference to Fig.1:

a. The FG (Fig.1) is brought down to a near ambient temperature by utilizing its heat content for auxiliary power generation by an ammonia (NH3) superheater and a NH3 turbine (Fig.1). The NH3 superheater is kept in the second chamber of the ceramic filter chambers to absorb maximum heat of the FG [5]. The NH3 after expansion is condensed in a water tank (at point 6 in Fig.1) cooled by cold nitrogen gas (CNG) (Fig.1). It is then circulated back by a pump to absorb heat of the FG and to repeat the cycle. After fly ashes are separated by ceramic filters (not shown in Fig.1), an electrostatic precipitator (ESP) and a fabric filter (FF), we employ N number of compressors (Fig.1) to compress the FG to a final pressure ~27 bars, by N isentropic compressions at equal increments of pressure. N=15 reduces the compression work considerably (see Appendix E). However, N=10 can also suffice and would be easier to implement, compression work would be more than that for N=15.
b. The FG is cooled in a heat exchanger (H.E.) after each isentropic compression to a temperature ~ 10°C below the boiling point of the component to be captured in the specified H.E (Fig.1). The cooling is done by CNG generated in the process. Two types

© 2022 Global Journals

of H.E.s are used. Type I is used to cool the FG to capture components with a boiling point above 0℃, and Type II is used to cool the FG to capture components with a boiling point below 0℃. The H.E.s are specially built to ensure good thermal conduction between the FG and the cold surroundings created by the CNG. The inside of the H.E.s are coated with acid-resistant films that are tolerant to a wide range of temperature variations (-192℃ to 300℃) in terms of structural changes. These are discussed in US Patent Application No. 15915007.

c. See Ref. 5 for more details on the H.E.s.
d. After water vapor (H2O), sulfur trioxide (SO3), nitrogen dioxide (NO2), and sulfur dioxide (SO2) are captured (each separately (Fig.1)), the FG is finally compressed to 26.5 to 27 bars by the Nth compressor and passed through a H.E. at e2 in Fig.1 kept at ~ -20℃ to -25℃ so that it attains at least -10℃ rapidly when it passes through the H.E. This condenses CO2 to liquid CO2 fast (Fig. 2).
e. After step d, the compressed FG undergoes three-stage turbine expansions (TE) (f-g-h-i in Fig.1) whereby N2O, NO and CO are condensed separately, and finally CNG is produced which is recirculated to capture each component separately (Fig.1). For details of the capture processes of these components, see Ref. 5 by the authors. Liquid CO2 is converted to dry ice by isentropic throttling (Fig.2) into a flash chamber cooled by CNG to a temperature - 95℃. This also condenses the CO2 vapor to dry ice and solidifies more the dry ice already produced by throttling. There is a provision to collect the dry ice without any exposure of the flash chamber to the atmosphere [5]. The dry ice then can be collected and compressed into slabs for storage.
f. The TE work aids compression (see Appendix E) and reduces the net energy requirement for capture.
g. The calculations on the temperature of CNG produced by TE, the compression work by N compressors, the TE work received by compressors, the cooling requirements by CNG are all given in Appendix E. The thermodynamics of the auxiliary power generation are however skipped to save space. The interested reader is referred to section I.2 of Ref. 5.

Appendix E: Scientific Analysis of the Energy Requirement in the Processes Involved

Estimation of the compression work

Since CO2 and N2 are the major constituents of the FG from coal and natural gas power plants, and since in our technology nitrogen gas is finally cooled to ~2°C above its boiling point, and this cold nitrogen gas is used to condense most of the component gases of small percentages, it is sufficient to assess the energy required to capture the entire CO2 in the form of liquid and dry ice and the energy required to cool the nitrogen gas. From the methods discussed above, it is obvious that the net work of production of liquid CO2 from the carbon capture, ΔWnet, will involve the difference ΔW, where ΔW = the work input to the N-stage compressor (Wc) – the work output (WTE) of the nitrogen turbine during expansion – the auxiliary energy generated during the capture of CO2. This ΔWnet is the energy of capture (EC) given in Tables A & B. Below we explain how we obtain the values.

From thermodynamic analysis, the specific work done on an N-stage isentropic compressor, Wc, is given as

$$W_c = c_P\, T_x\, N\, [(P_y / P_x)^{(1/N)\,(\gamma-1)/\gamma} - 1] \quad (1)$$

Where cp is the specific heat at constant pressure
Tx is the temperature at the inlet to each compressor stage
N is the number of stages
Py and Px are the final and initial pressures respectively
γ is the specific gas ratio.
The specific work output by a turbine, Wt, is given as

$$W_t = c_P\, (T_1 - T_2 \quad (2)$$

where T1 and T2 are the inlet and outlet temperatures respectively.

Here

$$T_1 / T_2 = (P_1 / P_2)^{(\gamma - 1)/\gamma} \quad (3)$$

for the isentropic expansion process.

By the energy conservation law, the work done on the compression of both the CO_2 and N_2 gases in the N-stage compressor is equivalent to the sum of the individual compressions, and for as much reduced compression work as possible, N (number of compressors) is taken as 15 in this study.

The properties of CO_2 are cp = 0.8464 kJ/kgK and γ = 1.288, the states are N = 15 stages, Py= 26.47 bars, Px=1.01325 bars. Then from Equation 1, the specific compression work on the CO_2 gas will be

© 2022 Global Journals

$$W_c = (0.8464)\,(298.15)\,(15)[(26.12)^{0.0149} - 1]$$
$$= 188.51 \text{ kJ/kg}$$

(Tx is the temperature of the $CO_2 + N_2$ mixture at state b1 in Fig.1, and it is assumed to be ambient, i.e. 25°C).

Also the properties of N_2 are cp = 1.0404 kJ/kgK and γ = 1.400, the states are N = 15 stages, Py = 26.47 bars, Px = 1.01325 bars. Then from Equation 1, the specific compression work on the N_2 gas will be

$$W_c = (1.0404)\,(298.15)\,(15)[(26.12)^{0.019} - 1]$$
$$= 297.79 \text{ kJ/kg}$$

Estimation of the cold N_2 gas temperature and the turbine work output

For the temperature (T2) of the nitrogen gas at stage i in Fig.1 (i.e. exhaust temperature) to be achieved at the boiling point of nitrogen (-195.8°C) (77.35 K) at atmospheric pressure (1.01325 bars) for the capture of CO2 (boiling point of -191.5°C), the temperature T_1 at stage g in Fig.1 from equation 3 will be

$$T_1 = T_2\,(P_1 / P_2)^{(\gamma - 1)/\gamma}$$
$$= 77.35 \text{ K } (26.471/\ 1.01325)^{0.2857}$$
$$= 77.35\ (2.5406) \text{ K}$$
$$= 196.52 \text{ K } (-76.63°C)$$

The pressure at stage h in Fig.1 at the boiling point of NO -152°C) (121.15K) for the capture of NO under pressure will be

$$P_h = P_g\,(T_h / T_g)^{\gamma/(\gamma-1)}$$
$$= 26.49\ (121.15/196.52)^{3.5}$$
$$= 4.87 \text{ bars}$$

Hence from Equation 2, the specific work output (Wt) by the three-stage turbine will be

Turbine Expansion Work Wt

$$W_t = 1.0404\ (196.52 - 121.15) + 1.0404\ (121.15 - 77.35) \text{ kJ/kg}$$
$$= (78.41 + 45.57) \text{ kJ/kg}$$
$$= 123.98 \text{ kJ/kg}$$

Estimation of the auxiliary power generated

The interested reader is referred to section I.2 on page 36 of Ref. 5.

Estimation of the net energy required for the capture of 1 ton of CO2

Using detailed thermodynamic analyses and applying the above mentioned process steps [5] to the case of the total power generated (1.4×10^{18} J) in the UK in 2010 [5a], we find the following:

(a) Assuming that the anhydrous ammonia could be raised to 200°C (which is possible if the initial FG temperature is around 250°C to 300°C), then the energy generated by the auxiliary power generator could be 19.96% of the total energy (1.4×10^{18} J) produced by the steam or gas turbine, assuming a ranking cycle of 35% efficiency for power generation. The calculation is based on the estimation of CO2 produced for the case study as carried out by Dr. Clifford Jones [5a] and detailed thermodynamic analysis as given in Ref. 5. If the FG temperature is such that the ammonia in the ammonia superheater can only be raised to temperature 100°C to 105°C, then the efficiency of auxiliary power (AUP) conversion from the heat of the FG is only 13.74%. Here, in the calculations of energy capture, we assume the 19.96% efficiency of AUP. We skip the details of these efficiency calculations and the specific processes involved to save space. The interested reader is referred to Ref. 5 for details.

(b) *Coal power plant.* Assuming the entire energy 1.4×10^{18} J under the case study is generated by coal then the total emission of CO2 is estimated to be 587 million tons. Our new technique is capable of capturing at a 100% rate, if needed. Thus, the auxiliary energy generated is 476 MJ/tCO2.

(c) *Natural gas power plant.* Assuming the entire energy 1.4×10^{18} J under the case study is generated by natural gas, then the total emission of CO2 is estimated to be 198 million tons. Our new technique is capable of capturing at a 100% rate, if needed. Thus, the auxiliary energy generated is 1411 MJ/tCO2.

An example of the calculation of the values of energy in Table A

In coal power plants the average constituents for 1.00 kg of dry FGs containing CO2 and N2 is assumed to be 0.25 kg for CO2 and 0.75 kg for N2. While in natural gas power plants the average constituents for 1.00 kg of dry FGs containing CO2 and N2 is estimated to be 0.15 kg for CO2 and 0.85 kg for N2 [Y] [YY].

Therefore, for 1.00 kg of dry FGs in a coal power plant, the compression work input for CO2 will be (0.25) kg x (188.51) kJ/kg = 47.13 kJ, and (0.75) kg x (297.79 kJ/kg) = 223.34 kJ for N2, given a specific

© 2022 Global Journals

compression work input of 47.13 kJ + 223.34 kJ = 270.47 kJ/kg for the mixture of the gases (0.25 kg CO2 plus 0.75 kg) N2 by the energy conservation law. Thus, for the capture of 1 kg of CO2, the compression work is Wc = 270.47/0.25 = 1082 kJ. For 1 ton of CO2, Wc = 1082 MJ (column A1 of Table A, for DMC=25%).

By the above method, the natural gas power plant will have a specific compression work input of 281.40 kJ/kg for the mixture of the gases. Thus, Wc = 1876 kJ/kg = 1876 MJ/tCO2 (Table A, column A1 for DMC=15%)

Since the specific work output of the turbine is 123.98 kJ/kg, the turbine work from the nitrogen in the FGs in a coal power plant is estimated to be (0.75) kg x (123.98) kJ/kg = 92.99 kJ, and that from a natural gas power plant is estimated to be (0.85) kg x (123.98) kJ/kg = 105.38 kJ.

Therefore, the net work input into the production of 0.25 kg of liquid CO2 at state n (Fig.1) from a coal power plant is estimated to be 270.47 – 92.99 = 177.48 kJ, which is equivalent to 709.92 kJ per kg of liquid CO2 at state n in Fig.1. This is shown in Column A2 of Table A for DMC=25%.

Also, the net work input into the production of 0.15 kg of liquid CO2 from a natural gas power plant is estimated to be 281.40 – 105.38 = 176.02 kJ. 176.02 kJ is the net compression work in NTEC per kg of FG containing 0.15 kg of CO2 and approx. 0.85 kg of N2 gas (i.e., the dry FG containing 15% CO2 gas), which is equivalent to 1,173.47 kJ per kg of liquid CO2 at state n. This is shown in Column A2 for DMC=15%.

We use the values of auxiliary energy as given above to calculate the net EC (ΔWnet) values. These are given for coal and natural gas in columns A3 and A4.

For N=15, using the above data we get Table A for the EC of CO2 with various dry mass concentrations (DMC). Similarly following the above theory we create Table B for N=10. It appears that N=10 would be a good choice since it would be easier and less costly to build the equipment of Fig.1. It is to be remembered that in NTEC we are mainly considering FG produced in coal or natural gas power plants that use normal air instead of pure oxygen for burning the fuel.

Cooling of the flue gas by the cold nitrogen gas produced in the CO_2 capture processes

Cooling the entire unreacted nitrogen gas of the FG to a temperature 1°C or 2°C above the boiling point (-196.5°C) of nitrogen using three-stage turbine expansions of the compressed FG initially at ~27 bars, and using the cold nitrogen gas thus produced to cool the incoming FG at various stages, and using only a fixed amount of water that can be repeatedly used, we find that the cold nitrogen gas cooled to -195°C is sufficient to cool the FG in various stages of capturing the component gases.

The heat gained by the cold nitrogen gas (assuming it is 75% of the FG; and assuming 10% H2O as steam and approximately 15% CO2 by volume) in rising from -195°C to the ambient temperature 25°C, is

$$H_N = 0.75.V.d_N.C_N(25-(-195)) = 0.75.V.d_N.C_N.220 = 165x1.2(kg/m^3)x1.03(kJ/kg.K) = 204\,kJ/m^3.$$

d = density and C = specific heat in gas-form.

The heat lost by the FG in the first cooling to temperature 45°C(step 7) is

H1 ≅ (0.75. dN.CN. + 0.1.dH2O(vapor).CH2O(vapor). + 0.15. dCO2(gas). CCO2(vapor)).(70-8) +(0.75. dN.CN. + 0.15. dCO2(gas). CCO2(vapor))(8-(-18)) +(0.75. dN.CN.)x(-10-(-55)) +(0.75. dN.CN.). (- 89-(-108)) + (0.75. dN.CN.)(-155-(-165)) = 1.2x62 +1.13x26+0.924x(19+45+10) = 172 kJ/m^3.

Thus, H1 is significantly less than HN, a condition necessary and sufficient to carry out all the cooling described in NTEC by only the cold nitrogen gas as said earlier.

After the auxiliary power generation, the temperature of the FG may be in the range 25°C to 70°C, depending on the initial FG temperature. We assume 70°C here.

NTEC captures CO2 from power plants at a cost much lower than the lowest cost of capture by current state-of-the-art technologies (CSOAs)

For example, a typical concentration in the FG from a coal power plant is 13.5% CO2 and 74% N2 by volume. This corresponds to a CO2 DMC of 22%. From Table A, column A3 we see that the EC is 329 MJ per ton of CO2. This is within 5% to 10% of electricity output per ton of CO2 emission. The energy penalty with CSOAs for oxyfuel combustion (DMC=100%) is 20% [YYY].

The energy penalty with CSOAs can easily reach 40% [YYYY]. With NTEC, as discussed earlier in section II.3, the maximum EC for oxyfuel combustion (Table A) is 188.5 MJ/ton of CO2 captured. If the energy is tapped from the output of a supercritical pulverized coal power plant [YYYYY], the CO2 emitted per MWh is 0.746 ton/MWh. This amounts to the maximum energy penalty by our technology, ~3.9%, without AUP (Table A). With AUP, there would be an energy surplus (not calculated in Table A). For a natural gas power plant a typical FG concentration corresponds to a CO2 DMC of 15% and the EC is –237 MJ, meaning that extra energy is generated during the

© 2022 Global Journals

capture. It should be noted that NTEC does not involve any additional cost of chemicals as used in current CSOAs. Thus, the cost is lower than the lowest cost of capture by CSOAs.

[Y] Rogers and Mayhew 1992

[YY] Engineering Thermodynamics: Work and Heat Transfer, Gordon F. C. Rogers, Gordon Frederick Crichton Rogers, Yon Richard Mayhew, Longman Scientific & Technical, 1992

[YYY] Energy Volume 103, 15 May 2016, Pages 709-714

[YYYY] Energy Environ. Sci., 2009, 2, 193–205

[YYYYY] Ref. 33 for sections I.2 to IV

© 2022 Global Journals